

Attention:
Jeff Stephens/Rae Dick
Town of Westford
55 Main Street
Westford, MA 01886

Report Date: 8/17/2021

Date Sampled: 8/16/2021

Date Received: 8/16/2021

Date of Analysis: 8/16/2021

Summary Report

Sample Location	E.coli per 100 ml	Lab#
Nashoba Valley Tiki Beach 1	2	231869
Nashoba Valley Tiki Pond 2	NT	
Summer Village Main Beach	12	231862
American Legion at LSFP	18	231863
Lakeside Meadows (on Nab Lake)	ND	231864
North Beach (on Nab Lake) N.I.A.	2	231865
Mary Lou Beach (on Nab Lake) N.I.A.	6	231865
Sandy Beach (on Nab Lake) N.I.A.	ND	231865
Noble Cove (on Nab Lake) N.I.A.	ND	231865
East Boston Camps (Girls Beach)	ND	231868
East Boston Camps (Daycare Beach)	4	231868
East Boston Camps (Boys Beach)	ND	231868
Edwards Beach	18	231867
Forge Village Beach	2	231867

NT=Not Tested
ND=None Detected

DPH Limit = 235 cfu/100ml
Method of Analysis: EPA 1603

Massachusetts State Certified
Laboratory # = M-MA1118


David L. Knowlton
Laboratory Director