

Attention:  
Jeff Stephens  
Town of Westford  
55 Main Street  
Westford, MA 01886

Report Date: 8/2/2017

Date Sampled: 8/1/2017

Date Received: 8/1/2017

Date of Analysis: 8/1/2017

Summary Report

| Sample Location                       | E.coli per<br>100 ml | Lab#             |
|---------------------------------------|----------------------|------------------|
| 1 Nashoba Valley Tiki Pond            | ND                   | 180274           |
| 2 Nashoba Valley Campers Beach        | 6                    | 180274           |
| 3 Forge Village Beach                 | 24                   | 180278           |
| 4 Summer Village Main Beach           | 66                   | 180280           |
| 5 American Legion at LSFP             | 56                   | 180281           |
| 6 Lakeside Meadows (on Nab Lake)      | ND                   | 180283           |
| 7 North Beach (on Nab Lake) N.I.A.    | ND                   | 180284           |
| 8 Mary Lou Beach (on Nab Lake) N.I.A. | ND                   | 180284           |
| 9 Noble Cove (on Nab Lake) N.I.A.     | 10                   | 180284           |
| 10 Edwards Beach                      | NT                   | to be tested 8-2 |
| 11 Sandy Beach (on Nab Lake) N.I.A.   | NT                   | to be tested 8-2 |
| 12 East Boston Camps (Girls Beach)    | 8                    | 180287           |
| 13 East Boston Camps (Day Camp Beach) | 0                    | 180287           |
| 14 East Boston Camps (Boys Beach)     | ND                   | 180287           |

RECEIVED

AUG 02 2017

WESTFORD  
BOARD OF HEALTH

NT=Not Tested  
ND=None Detected

DPH Limit = 235 cfu/100ml  
Method of Analysis: EPA 1603

Massachusetts State Certified  
Laboratory #MA1118

David L. Knowlton  
Laboratory Director