

Attention:
Jeff Stephens/Rae Dick
Town of Westford
55 Main Street
Westford, MA 01886

Report Date: 6/26/2018

Date Sampled: 6/25/2018

Date Received: 6/25/2018

Date of Analysis: 6/25/2018


Summary Report

Sample Location	E.coli per 100 ml	Lab#
1 Nashoba Valley Tiki Pond	8	191020
2 Nashoba Valley Function Pond	6	191020
3 Forge Village Beach	16	191022
4 Summer Village Main Beach	4	191023
5 American Legion at LSFP	8	191024
6 Lakeside Meadows (on Nab Lake)	8	191025
7 North Beach (on Nab Lake) N.I.A.	52	191026
8 Mary Lou Beach (on Nab Lake) N.I.A.	82	191026
9 Edwards Beach	20	191022
10 Sandy Beach (on Nab Lake) N.I.A.	12	191026
11 Noble Cove (on Nab Lake) N.I.A.	44	191026
12 East Boston Camps (Daycare Beach)	18	191028
13 East Boston Camps (Boys Beach)	2	191028
14 East Boston Camps (Girls Beach)	3	191028

NT=Not Tested
ND=None Detected

DPH Limit = 235 cfu/100ml
Method of Analysis: EPA 1603

Massachusetts State Certified
Laboratory # = M-MA1118


David L. Knowlton
Laboratory Director